



PHIFER

INCORPORATED

31 March 2014

DRAPER INC.

Sent Via E-mail: jmiller@DraperInc.com

Re: Flame Retardance Certificate

PHIFER INCORPORATED certifies that the material described below manufactured in Tuscaloosa, Alabama, U.S.A., and furnished by our firm:

Phifer SheerWeave Vinyl Coated Fiberglass Fabric: SheerWeave 1000 (All Colors)

is in compliance with the following standard(s):

1. Flammability per California Administrative Code, Title 19, Public Safety, Section 1237, Flame Resistance Small Scale Test. (California Registration No. F-44207)
2. National Fire Protection Association, NFPA No. 101, "Life Safety Code", Class "A" rating. (Tested in accordance to ASTM E84-09a, Surface Burning Characteristics of Building Materials.)
FLAME SPREAD INDEX = 15 SMOKE DEVELOPED VALUE = 250
3. International Building Code (IBC), Section 903.1, (Tested in accordance to ASTM E84), Class "A" rating.
4. NFPA 701, Standard Methods of Fire Tests for Flame Propagation of Textiles and Films 2010 Edition (Test 1, Small Scale).
5. NFPA 701, Standard Methods of Fire Tests for Flame Propagation of Textiles and Films, 2010 Edition (Test 2, Large Scale).
6. BS EN ISO 15025:2002 - Protection against heat and flame - Method of test for limited flame spread (Procedure A - Surface Ignition). As cited by BS 5867-2:2008 - British Standard Specification for Fabrics for curtains, drapes and window blinds; Part 2: Type "B" Performance Requirements.

If you have any questions or need further information, please contact me at 1-800-633-5955 Ext. 3075.

Sincerely,

PHIFER INCORPORATED

Keith Euerle

Director, Specialty Textiles Testing and Analysis